

**GOVERNMENT OF INDIA
MINISTRY OF POWER**

**LOK SABHA
UNSTARRED QUESTION NO.2756
TO BE ANSWERED ON 27.12.2018**

REPLACEMENT OF BURNT TRANSFORMERS

†2756. SHRI LAXMAN GILUWA:

**Will the Minister of POWER
be pleased to state:**

(a) whether most of the 10 KVA and 16 KVA transformers which were installed under rural electrification scheme in villages of Paschim Singhbhum in Jharkhand are burnt but they have not been replaced with the new ones due to which there is no electricity in those villages;

(b) if so, the details thereof; and

(c) the steps taken by the Government to replace the burnt down transformers in the villages of the above said districts?

A N S W E R

**THE MINISTER OF STATE (INDEPENDENT CHARGE) FOR POWER
AND NEW & RENEWABLE ENERGY**

(SHRI R. K. SINGH)

(a) to (c) : As reported by Jharkhand Bijli Vitran Nigam Limited (JBVNL), as many as 1455 10 KVA and 16 KVA Distribution Transformers (DTs) are burnt and identified for replacement in different villages of District West Singhbhum, Jharkhand. Of these, 575 burnt DTs of 10/16 kVA have already been replaced with 25/63 kVA as on 27.11.2018.
